## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRRES20193076

Address: 4525 SW NAUTILUS PL, LEES SUMMIT, MO 64082

Inspected On: Friday, September 04, 2020

**Inspected By:** Patrick Schonfeldt

Expiration Date: 10/2/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Outcome: Date:

Occupancy Inspection - Patrick Schonfeldt Temporary C of O Friday, September

Codes Residential 04, 2020

Corrective Action Required:

1 Misc - Post permanent address

- Complete final grade and sod

- Splash blocks at all downspout and sump pump discharge

locations, minimum discharge 36" from foundation

- Seal all penetrations in siding, seal along top of meter can and AC

disconnect