

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200878  
Address: 1717 SW 26TH TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Friday, September 04, 2020

Informational:

1	Miscellaneous Correction	<b>**OK TO INSULATE AND SHEET ROCK**</b> — DO NOT COVER EGRESS WINDOWS —  -ENSURE POSTS ARE NOT IN CONTACT WITH THE GROUND OR RATED FOR GROUND CONTACT -INSTALL EGRESS WINDOWS IN BED 3 & 4
---	--------------------------	---

**Comments:**