

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201552
Address: 1512 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 08, 2020

Corrective Action Required:

1	Misc	9/8 - Unable to check inspection items in basement due to standing water, pump out water and reschedule when dry
		- Complete gas line installation at fireplace
		- Gas pressure test required

Comments: