

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200754
Address: 2513 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Failed	Friday, September 04, 2020

Corrective Action Required:
2 Misc JOHN DIMAURO 09/04/2020 3:05 PM

FAILED POST POUR INSPECTION

THE DRIVEWAY APPROACH HAS A CROSS SLOPE GREATER THAN 2.0 PERCENT AND IS OUT OF ADA COMPLIANCE.

MAKE CORRECTIONS TO THE DRIVEWAY APPROACH AND CALL FOR AN INSPECTION PRIOR TO POURING THE REPLACEMENT SECTIONS.

Comments: