

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201012
Address: 1866 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Thursday, July 02, 2020

Corrective Action Required:

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	----------------------	---

****CLEAN THE STREET AND REESTABLISH THE EROSION CONTROL**

Corrective Action Required:

2	Misc	Large amounts of sediment on NE Park Ridge Dr. from failed erosion control silt fence. Existing control silt fencing needs to be re-stake and street cleaned.
---	------	---

Comments: