

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193319
Address: 4032 SW BENZIGER DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 08, 2020

Corrective Action Required:

1	Misc	Provide copper from main to setter and 10' beyond setter - uncover copper from gravel cover at main connection to street, uncover copper from meter pex connection if applicable to verify at least 10' copper passed meter
---	------	---

Comments: