

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20191872  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Street - Surface Course</b>		Failed	Tuesday, September 08, 2020

Corrective Action Required:

1	Misc	John DiMauro 9/8/2020 11:15 AM
---	------	--------------------------------

An area of the street has been identified as defective and is not allowing water to properly drain. The area is at the intersection of SW Georgetown DR & SW Merryman DR. Corrective action is required as soon as possible. Photos of the ponding area are uploaded to the permit.

Additionally, the road entrances need to be properly blocked off to keep traffic out of the areas until the streets are complete and have been accepted for use. Examples include street signs installed and any repairs needed.

**Comments:**