

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200368
Address: 1614 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Tuesday, September 08, 2020

Corrective Action Required:

2	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. - RE ESTABLISH AND MAINTAIN SILT FENCE AT FRONT OF LOT - CLEAN MUD AND DEBRIS BUILDUP AT STORM SEWER INLET AT FRONT OF LOT - EROSION CONTROL REQUIRED AT BACK OF LOT
---	----------------------	---

Comments: