

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201493
Address: 4724 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Wednesday, September 09, 2020

Corrective Action Required:

1	Misc	-Install a #4 bonding jumper from the bus bar where to grounding electrode conductor is connected to to the grounded bus bar where the service grounded conductor is connected to
---	------	---

Comments: