

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201133
Address: 1041 NE SAM WALTON LN, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, September 09, 2020

Corrective Action Required:

1	Miscellaneous Correction	-LABEL ELECTRICAL PANEL -PROVIDE ADA ACCESSIBILITY IN BREAK ROOM -MOVE BATHROOM SIGNS TO LATCH SIDE -PROVIDE OPEN TOILET SEAT IN ADA BATHROOM -PROVIDE INSULATION BIB ON PIPE IN AFA BATHROOM -ADD ADA COUNTERTOP FOR P.O.S.
---	-----------------------------	---

Comments: