

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191536
Address: 1109 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, September 09, 2020

Corrective Action Required:

2	Misc	-Fix ground fault condition for rear porch gfci receptacle -Provide a smoke and CO alarm outside 1st fl bedroom -Provide gfci protection for dish washer outlet per NEC 210.8(D). Install dual protection gfi and afci for circuit -Provide AFCI protection for all outlets required per NEC 210.12. All outlets located in the house (except garage, bathroom, unfinished basement, outdoor, attic) shall be afci-protected. Outlets include lighting and receptacle outlets as well. Please read this section of the code
---	------	--

Comments: