

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193016
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Air Test	Ronald Paynter	Passed	Wednesday, September 09, 2020

Informational:
1 Misc Test gauge calibration sticker expired last month. United Rentals brought out new certificate of calibration and sticker for the test gauge. All segments of sanitary lines passed their air test. RP 9-9-20

Comments: