

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193016

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Mandrel	Ronald Paynter	Passed	Wednesday, September 09, 2020

Informational:

1 Misc

They had the wrong size mandrel (7.11) for testing. United Rental brought out the right size mandrel (7.37). The mandrel passed through all sanitary lines and inverts. RP 9-9-20

Comments: