

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200759
Address: 2417 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, September 10, 2020

Informational:

1 Misc

- PORTAL FRAMING ONLY -
- STHD14 NAILED OFF, HEADER NAILING PATTERN APPROVED -

Corrective Action Required:

2 Misc

GENERAL-
-concrete encased electrode grounding connection to remain accessible (provide access panel COF) -

FRAMING-

-2x10 ridge required at covered front porch per plan

Comments: