

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192520
Address: 704 SE OLDHAM CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Field Services	Tom Taylor	Failed	Thursday, September 10, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | 1. Remove and replace failed or ponding areas in parking lot.
2. Complete asphalt in entrance areas at CG-1 curb.
3. Complete drivable turf area.
4. Check on the elevation of the field inlet in the drivable turf area. May be too high and needs adjustment.
5. Remove card broad rap from street light in main parking lot in front.
6. Install erosion control devices through out project. |
|---|------|---|

Comments: