CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202588

Address: 2350 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Residential Michael Harkins Passed Thursday, September

10, 2020

Informational:

1 Misc - 3RD PARTY FOOTING SIGNED & SEALED BY DAVID AINSWORTH -

- COMMENTS: UFER GROUND LOCATED IN EAST SIDEWALL A FEW FEET BEHIND

GARAGE WALL-

Comments: