

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192520
Address: 704 SE OLDHAM CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, September 10, 2020

Corrective Action Required:

1	Misc	- NO OCCUPANCY INSPECTIONS PERFORMED - - OK TO INSTALL DESK & PARTITIONS -
---	------	---

Corrective Action Required:

2	Misc	- GFCI AT METER CAN - - GFCI WOMEN'S RESTROOM - - LABEL SERVICE PANEL BREAKERS - - PROVIDE PLUGS AT SERVICE PANEL OPEN SLOTS - - LABEL DISCONNECT RTU - - AIR COMPRESSOR DISCONNECT ACCESSIBLE - - PLUG KNOCKOUT JBOX ABOVE OVERHEAD DOOR - - LABEL MAIN DISCONNECT - - SWITCH FOR HEATER AT CATWALK OVER 6'6" - - THRESHOLDS AT FRONT & REAR DOORS EXCEEDS 1/4" - - CHECK GROUNDING LIGHT POLES -
---	------	--

Comments: