

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200268
Address: 2305 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Friday, September 11, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">•Fireblock top of cubbie- main level shelving by stairs•Terminate NM (romex) at ceiling in living room, front entry•Continuous 2x4 studs at foyer for load bearing walls•Strap all DWV piping 2" or smaller at midpoint- basement•Anchor bolt required within 12" of plate break - basement, left of sub panel
---	------	--

OK TO INSULATE
DO NOT ROCK RE-INSPECTION REQUIRED

Comments: