

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193668  
Address: 1905 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Friday, September 11, 2020

Corrective Action Required:

1	Miscellaneous Correction	<b>**DO NOT INSULATE**</b> -POST ADDRESS BEFORE NEXT INSPECTION -CORRECT OVER-NOTCHED STUD IN GARAGE -SEAL GAPS IN FIRE BLOCK AT DUCT CHASE IN GARAGE -PATCH HOLE IN SUB FLOOR BY ENTRY DOOR-NOT PRESENT ON PREVIOUS INSPECTION -SEAL GAPS IN FIRE BLOCK AT DEAD SPACE AT DUCT CHASE IN BED 2 -SEAL HOLES IN SUB FLOOR IN MASTER BATH NOT PRESENT DURING LAST INSPECTION -ADDRESS BEAM CONNECTIONS IN KITCHEN AND DINING THAT ARE WELDED INSTEAD OF BOLTED PER PLANS -COMPLETE PLUMBING IN MASTER BATH
---	--------------------------	--

Comments: