

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200481
Address: 1912 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, September 11, 2020

Informational:

1	Miscellaneous Correction	-PORTAL FRAMING; NAIL PATTERN,AND STRAPS COMPLETE - (2) 24X36 PIERS FOR DECK
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	**DO NOT INSULATE** -SEAL PENETRATION IN BOTTOM PLATE NEAR GARAGE ENTRY-MUD ROOM -COMPLETE PLUMBING MASTER BATH TRAP -SEAL GAP IS N FIREBLOCK AT DEAD SPACE BETWEEN MASTER BATH AND SECOND BATH --BOND GAS LINE
---	--------------------------	--

Comments: