

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20200707  
Address: 860 NW BLUE PKWY, Unit:U, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Failed	Friday, September 11, 2020

Corrective Action Required:

1	Misc	- PROVIDE COVER PLATES RECREPTACLES AT SINK & CHECKOUT - - PROVIDE BACKFLOW DEVICE AT BEVERAGE DISPENSERS - - PROVIDE AIR GAP AT COFFEE, DISHWASHER & ICE MACHINE - - PROVIDE ( DOOR SHALL REMAIN UNLOCKED DURING BUSINESS HOURS SIGN ) - - PROVIDE 36" OUTSWING DOOR FOR DRESSING ROOM PER PLAN - - ADDRESS CONDUIT ABOVE FLOOR AT CHECKOUT ( TRIP HAZZARD) -
---	------	---

**Comments:**