

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193016
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	Ronald Paynter	Passed	Monday, September 14, 2020

Informational:
1 Misc Meet with Rudy and pulled another 3 samples. Delivered samples to
Keystone Laboratories for testing. RP 9-11-20

Informational:
2 Misc Received test results from Keystone Laboratories. All 3 samples passed their
second Bac T test. RP 9-14-20

Comments: