

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201848
Address: 1513 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 15, 2020

Corrective Action Required:

1	Misc	- Connect interior drain tile to sump basin - Interior drain tile to reach opposite end of foundation footing if running diagonally across basement floor - Seat DWV on gravel base N wall
---	------	--

Comments: