

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202513
Address: 1527 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 15, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Fireblock vertical to horizontal at furred down
- Seal gaps at Fireblock between top plate and foundation wall - bedroom closet, rec room S wall
- Seal penetration in Fireblock top plate at bedroom closet for pex |
|---|------|--|

Comments: