



### **PLAN REVIEW CONDITIONS**

September 16, 2020

SCHARHAG ARCHITECTS  
6247 BROOKSIDE BLVD STE 204  
KANSAS CITY, MO 64113

Permit No: PRCOM20202943  
Project Title: MIRACLE EAR  
Project Address: 202 NW OLDHAM PKWY, LEES SUMMIT, MO 64081  
Parcel Number: 62140031600000000  
Location: SUMMIT SHOPPING CENTER LOT 1  
Type of Work: CHANGE OF TENANT  
Occupancy Group: BUSINESS  
Description: TENANT FINISH FOR HEARING AID CONSULTING AND TESTING

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

<b>Fire Plan Review</b>	<b>Reviewed By: Michael Weissenbach</b>	<b>Approved</b>
<b>Building Plan Review</b>	<b>Reviewed By: Joe Frogge</b>	<b>Pending</b>

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

2. 2018 IBC 1109.12.3 Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: At least 36" of reception counter to be maximum 36" tall. (can be verified during inspections)

3. 2017 NEC Article 517.13 Grounding of Receptacles and Fixed Electrical Equipment in Patient Care Spaces. Wiring in patient care spaces shall comply with 517.13(A) and (B).

(A) Wiring methods. All branch circuits serving patient care spaces shall be provided with an effective ground-fault current path by installation in a metal raceway system, or a cable having a metallic armor or sheath assembly. The metal raceway system, metallic cable armor, or sheath assembly shall itself qualify

as an equipment grounding conductor in accordance with 250.118.

(B) Insulated Equipment Grounding Conductors and Insulated Equipment Bonding Jumpers.

(1) General. The following shall be directly connected to an insulated copper equipment grounding conductor that is clearly identified along its entire length by green insulation and installed with the branch circuit conductors in the wiring methods as provided in 517.13(A).

1. The grounding terminals of all receptacles other than isolated ground receptacles.

2. Metal outlet boxes, metal device boxes, or metal enclosures.

3. All non-current-carrying conductive surfaces of fixed electrical equipment likely to become energized that are subject to personal contact, operating at over 100 volts. (see code for exceptions)

(2) Sizing. Equipment grounding conductors and equipment bonding jumpers shall be sized in accordance with 250.122.

Action required: Modify drawings to show that all circuits in patient care areas will have redundant ground system.

4. 2018 IBC 2902.3 Employee and public toilet facilities. For structures and tenant spaces intended for public utilization, customers, patrons and visitors shall be provided with public toilet facilities. Employees associated with structures and tenant spaces shall be provided with toilet facilities. The number of plumbing fixtures located within the required toilet facilities shall be provided in accordance with Section 2902 for all users. Employee toilet facilities shall be either separate or combined employee and public toilet facilities.

Exception: Public toilet facilities shall not be required for:

1. Parking garages where operated without parking attendants.

2. Structures and tenant spaces intended for quick transactions, including takeout, pickup and drop-off, having a public access area less than or equal to 300 square feet.

Action required: Comment is for informational purposes. Restroom must remain accessible to patrons. Work Room must not be used for storage.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***