

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200162  
Address: 1709 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, September 16, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE ADEQUATE EROSION CONTROL AND CLEAN UP TRASH AND DEBRIS FROM STREETS BEFORE FURTHER SIGNS INSPECTION - MINIMUM OF (2) 2X4 BEARING STUDS REQUIRED PER PLANS -PROVIDE HANGERS OR 1 1/2" BEARING FOR RAFTERS OVER ENTRY -PROVIDE HANGERS FOR JOISTS OVER ENTRY -SEAL DEAD SPACE AT DOUBLE WALL AT STAIRS TO PREVENT VERTICAL TO HORIZONTAL FIRE SPREAD- USE APPROVED MATERIALS PER R302.11.1 -PROVIDE HANGER OR 1 1/2" BEARING FOR STRUT SUPPORTING RIDGE LANDING ON FACE OF LVL IN GREAT ROOM -PROVIDE VERTICAL FIRESTOP IN BASEMENT BATH OFF OF STORAGE ROOM FUR OUT WALL WHERE GREATER THAN 10' HORIZONTAL -FIRESTOP DEAD SPACE IN BASEMENT FIREPLACE- USE APPROVED MATERIALS PER R302.11. FIREBLOCKING REQUIRED BETWEEN FLOORS AND JOIST SPACES PER R1003.19- -ADDRESS MISSING DOUBLE LVLS AT HEADERS REQUIRED PER HEADER SCHEDULE -ADDRESS SINGLE LVL HEADERS USED IN PLACE OF DOUBLE 2X10 HEADERS REQUIRED PER HEADER SCHEDULE
---	-----------------------------	--

-ADDRESS ALL HEADERS TO BEAR ON MINIMUM OF (2) 2X4 PER FRAMING  
NOTES

**Comments:**