

Temporary Certificate of Occupancy

Permit #: PRCOM20192520
Address: 704 SE OLDHAM CT, LEES SUMMIT, MO 64081
Inspected On: Wednesday, September 16, 2020
Inspected By: Robb Popp
Expiration Date: 10/8/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Temporary C of O	Wednesday, September 16, 2020

Corrective Action Required (for Full C of O):

2 Misc Planning:
Completion of landscaping

Field Engineering:

1. Remove all forming from Curb inlets throughout project
2. Remove plastic off of ADA mat off of Oldham Rd
3. Fill abandoned sewer area at entrance to skate rink
4. Follow up with consultant engineer about existing elevation of field inlet
5. Maintain erosion control until 70% vegetation has been established
6. Finish Landscaping

