

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 640812001 NW SHAMROCK AVE, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Proof roll parking lot</b>	Ronald Paynter	Failed	Wednesday, September 16, 2020

Corrective Action Required:

1	Misc	They had a tandem dump truck with a 19.25 ton load. Since it was a private parking lot, I said it would be ok. Terracon was also present to witness the proof roll. The parking lot failed in 7 different locations. Norm is looking at cutting those sections out and adding Portland to the base, followed by geo grid and more rock. RP 9-16-20
---	------	--

Comments: