

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200878
Address: 1717 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, September 17, 2020

Informational:

1	Miscellaneous Correction	INSPECTION DENIED DUE TO LACK OF EROSION CONTROL 9/17/20
---	--------------------------	--

****OK TO INSULATE AND SHEET ROCK****
—DO NOT COVER EGRESS WINDOWS—

-ENSURE POSTS ARE NOT IN CONTACT WITH THE GROUND OR RATED FOR GROUND CONTACT

-INSTALL EGRESS WINDOWS IN BED 3 & 4

Corrective Action Required:

2	Miscellaneous Correction	FROM FAILED EROSION CONTROL INSPECTION 9/16/20:
---	--------------------------	---

-Deficient erosion control installation, shall be in compliance within two days. No further inspections until complete

-Street cleanup required immediately. No further inspections until complete

-Remove trash from site

-Remove overgrown weeds and vegetation

-Maintain gravel filter at driveway

Comments: