David P. Ainsworth, P.E.
104 N Central St, Buckner, MO 64016
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

September 14, 2020

Mr. Paul Miller
Bellah Homes, LLC
P.O. Box 346
Lee's Summit, MO 64063

Re: 3229 SW Mary St.
Lee's Summit, MO

Dear Mr. Miller:

It is my understanding that the plans call for 2x12 ridge rafters over Bedroom #2 and #4 but 2x10 ridges rafters were installed. These 2x10 ridge rafters are adequate for the imposed loads.

In summary, the roof framing as installed is adequate for the imposed loads.

Cordially,

David P. Ainsworth

David P. Ainsworth, P.E.

STATE OF MISSOURI
DAVID PAUL AINSWORTH
ENGINEER
E-18038
PROFESSIONAL ENGINEER

9-14-20