

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201498
Address: 140 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Passed	Thursday, September 17, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | - UFER GARAGE WALL NEAR FURNACE -
- (2) DECK PIERS POURED WITH DRILLED PIERS - |
|---|------|---|

Comments: