

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193693  
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Michael Harkins	Passed	Thursday, September 17, 2020

Corrective Action Required:

1	Miscellaneous Correction	-WELD TEST PERFORMED ON GROUND HOOD WHERE EXITS ROOF.  RE-INSPECT HOOD ONCE INSTALLED IN PLACE.  -FIRST LAYER OF WRAP OK -SECOND LAYER OF WRAP OK
---	--------------------------	--

**Comments:**