

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20193345  
Address: 1816 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, September 17, 2020

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- Label dedicated receptacle in garage as not GFCI protected</li><li>- AFCI protection required per code E3902.16</li><li>- Bathroom circuit(s) 1st and 2nd floor are not allowed to supply any other outlets, besides bathroom sink receptacles. E3703.4</li><li>- Kitchen circuit is not allowed to supply exterior GFCI receptacle at back porch E3703.2</li><li>- Place splash blocks at all downspout and sump pump discharge locations, minimum discharge distance 36" from foundation</li><li>- Obtain lawn irrigation system permit</li></ul> |
|---|------|---|

Comments: