

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193630  
Address: 1812 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector: | Outcome: | Date:                        |
|---|------------|----------|------------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Robb Popp  | Failed   | Thursday, September 17, 2020 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -PROVIDE SOD<br>-PROVIDE SPLASH BLOCKS/ DRAINAGE 36" AWAY FROM FOUNDATION<br>-OBTAIN LAWN IRRIGATION PERMIT AND BACKFLOW CERTIFICATION<br>-PAY ALL FEES BEFORE FINAL C.O. |
|---|------|---|

**Comments:**