

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193705
Address: 2716 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, September 17, 2020

Corrective Action Required:

1	Misc	-License tax shall be paid prior to issuance of any occupancy -Approval required from: Fire -Install breaker lock for out-of-sight water heater, or install disconnect for WH -The terminations of b-vent shall be min 8 ft from parapet wall
---	------	--

Comments: