

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20201546  
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Construction Inspection</b>	Joe Starlin	Partial	Wednesday, September 16, 2020

Informational:

1	Misc	John Jackson 8/27/20 Thursday Contractor laid 2" Copper to 1.5" Blue Ploy to proposed building. 2" Copper from main to meter. Contractor plans to install three more meters another 1.5" , 2" , & 1" . See document pictures. 9-16-20 1:39PM They have installed a 2" water line to a hand pump.
---	------	--

**Comments:**