

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193192  
Address: 1820 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Friday, September 18, 2020

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- GFCI protection required at front bath receptacle</li><li>- Label dedicated outlet in garage as not GFCI protected</li><li>- Seal all penetrations in siding, seal along top of AC disconnect</li><li>- Remove sod cover blocking storm sewer inlet(s) at swale backyard</li><li>- Place splash blocks at all downspout and sump pump discharge locations, minimum distance 36" from foundation</li><li>- Obtain lawn irrigation system permit</li></ul> |
|---|------|--|

**Comments:**