

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201406
Address: 4701 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Friday, September 18, 2020

Corrective Action Required:

1	Misc	-Tempered glass windows required where within 24" of basement door
		-Verify that's there are column pad underneath column
		**Have engineer address what needs to be done, or just cut out the floor and install a new pad
		 **OK TO ROCK

Comments: