

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172531
Address: 257 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Tuesday, September 08, 2020

Corrective Action Required:

1	Misc	- TOP COAT & STRIPPING PARKING LOT - - PROVIDE HAMMER ARRESTORS DISHWASHERS - - 301 GFCI AT RANGE, TIGHTEN SELF CLOSING HINGES ENTRY DOOR - - 302 BROKEN WINDOW BATHROOM, TIGHTEN SELF CLOSING HINGE ENTRY DOOR - - 202 GFCI NEXT TO REFRIGERATOR - - 204 ADA INSULATE PIPES UNDER SINK - - 2-6 ADA INSULATE PIPES UNDER SINK - - 208 NAIL JOIST HANGER DECK - - 104 NAIL JOIST HANGER DECK - - FIRE ALARM PANEL ROOM FIRE CAULK CEILING - - SPRINKLER ROOM FIRE CAULK CEILING - - GUARDRAILS AT NORTH & SOUTH A/C CONDENSORS - - PROVIDE TAMPER PROOF CAPS A/C CONDENSORS - - G-2 GUARDRAIL SHALL BE 42" - - G-3 GUARDRAIL SHALL BE 42", 36" CLEARANCE - - G-4 GUARDRAIL SHALL BE 42" - - G-8 " " - - G-10 " "
---	------	--

Comments: