

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201729
Address: 1863 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Khanh Nguyen	Partial	Monday, September 21, 2020

Informational:
1 **NAILING OF THE BRACE WALL IS OK; HOWEVER, INSTALL THE 2" ANCHOR WASHERS. CHECK THIS AT ROUGH-IN INSPECTION

Comments: