

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200989
Address: 2927 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Tuesday, September 22, 2020

Corrective Action Required:

1	Misc	-Final grade and sod -Obtain lawn irrigation system permit -minimum 36" splash blocks at downspouts -Sump to discharge minimum 36" from foundation -Handrail required at garage steps, 4 rises -Open outlet and switch box(s) at fireplace -Final driveway inspection
---	------	---

Comments: