

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200261
Address: 340 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Robb Popp	Failed	Tuesday, September 22, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE MIDPOINT STRAP ON VERTICAL DWV 2" AND SMALLER -PROVIDE PROTECTION PLATES ON DWV LESS THAN 1 1/4" FROM FACE OF STUD -PROVIDE HANGER ON HORIZONTAL DWV AT ELBOW
---	--------------------------	--

Comments: