

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 64081  
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Proof roll parking lot</b>	Ronald Paynter	Passed	Tuesday, September 22, 2020

Corrective Action Required:

1	Misc	They had a tandem dump truck with a 19.25 ton load. Since it was a private parking lot, I said it would be ok. Terracon was also present to witness the proof roll. The parking lot failed in 7 different locations. Norm is looking at cutting those sections out and adding Portland to the base, followed by geo grid and more rock. RP 9-16-20
---	------	--

Informational:

2	Misc	Bair Excavating used a semi hauler with a 20 ton load for the proof roll, which would be allowed on this private parking lot. Terracon was also present to witness the proof roll. All existing soft spots have firmed up and the parking lot passed it's proof roll. RP 9-22-20
---	------	--

Comments: