CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200044

Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

DE - Curb New/Replacement Joe Starlin Partial Tuesday, September

22, 2020

Informational:

1 Misc 9-21-20 10:49am They are forming up curb along the east side of the site.

1:15pm They are still working on setting forms.

9-22-20 2:00pm The crew have set curb in front of the building and on the west side of the site. They started to set up on the south side again and I had

to stop them. The proof roll did not pass on the south side.

Comments: