

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201649
Address: 400 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	Robb Popp	Failed	Wednesday, September 23, 2020

Corrective Action Required:
3 Miscellaneous -ADJUST NORTH GATE TO BE SELF CLOSING AND LATCHING
 Correction -BOND ALL METALLIC BOXES AND ALL DEVICES WITHIN
 -PROVIDE WATER TIGHT CONNECTIONS BETWEEN SWITCH BOX AND
 DISCONNECT AND SWITCH BOX AND RECEPTACLE BOX

Comments: