

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Partial	Wednesday, September 23, 2020

Corrective Action Required:

1	FOURTH FLOOR	AREA"E"- UNITS- 435,436,437,438,439,440,461,441,442,459-443-459-461-462-463-464-465-46 0- 426;444,447,448,449,450,451,457,424A, 425A Corridor 419 to room 439 ok -CORRIDOR 419,422,426, 427, 429, CEILINGS & WALLS -
---	--------------	--

Corrective Action Required:

2	THIRD FLOOR	AREA "D" CORRIDOR 412,  Section "E" 345-344-343- 342-361-362-363-341-364-340-322-326-327, 329, -corridor framing ceiling -321A, 324A, 325A, 337, 338, 339, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360,365, 366, 367 Corridor 319 to room 364 ok Corridor 322, 326, 327, 329,
---	-------------	--

Corrective Action Required:

3	SECOND FLOOR	SECTION "D" CORRIDOR FRAMING CEILING 312,  Section "E" Ok- 224A,237,238,239,240,241,242,243,244,245, 246, 261,262.
---	--------------	---

225A, 226, 264,265,266,267 -  
-,247,249,250,251,252, 253,254,256,257,258,259,260,

-248- SEAL DEAD SPACE AT FUTURE SHAFT

Corridor 219 to room 240 ok  
Corridor 222 to stairs ok  
- CORRIDOR 222 FROM STAIRS TO END OF CORRIDOR 226 -  
SECTION "E"  
CORRIDOR FRAMING CEILING 229,

SECTION "D"  
CORRIDOR CEILING FRAMING 212,

Corrective Action Required:  
4 FIRST FLOOR

BUILDING "B"

-CORRIDOR 103 LINE 4.3 TO 2 \*\* METAL FRAMING ONLY

BUILDING "C" AREAS OK;

-LOBBY EXTERIOR EAST WALL \*\*METAL FRAMING ONLY -  
- NORTH RETAIL ALL ROUGH -

Section "E" OK-121,122,123,124,125, 126, 127, 128, 129, 130, 131, 132, 133,  
134, 135, 136, 137, 138,

Corridor 119 to room 125 ok  
Corridor 122 ok  
CORRIDOR CEILING 112, 129,  
-Corridor 126 Metal Stud Framing from north exit to line 8.6

-CORRIDOR 124- PROVIDE HANGERS/ CONNECTIONS ON FLOOR JOISTS BOTH  
ENDS-

-ROOM 132-  
-SEAL HOLE IN CORRIDOR WALL AT CLEAN OUT

Informational:  
5 STAIR TOWER 3

- STAIR TOWER "C" -  
- ALL ROUGH APPROVED -

**Comments:**