

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191295
Address: 807 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	John Morris	Failed	Thursday, September 24, 2020

Corrective Action Required:

1	Misc	-Gas pressure test failed, must hold minimum 10 psi for 15 minutes -Connect gas piping to appliance
---	------	--

Comments: