

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200127
Address: 2931 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, September 24, 2020

Corrective Action Required:

1	Misc	-Final grade per approved plot plan and sod -Remove paint covers from smoke and carbon monoxide alarms - master bed, basement -Label all dedicated receptacles as non-GFCI protected In garage and unfinished basement
---	------	--

Comments: