

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202595
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Robb Popp	Failed	Thursday, September 24, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE BONDING BUSHING BETWEEN SEVICE AND DISCONNECT
---	--------------------------	--

Comments: