

DEVELOPMENT SERVICES

| | |
|---|---|
| Building Permit - Commercial Project Title: Saint Luke's East - NE Parking Lot Expansion and Generator Work Desc: NEW OTHER (COMMERCIAL) | Permit No: PRCOM20202959 Date Issued: September 24, 2020 |
|---|---|

| | |
|--|---|
| Project Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086 Legal Description: SAINT LUKES HOSPITAL OF LEES SUMMIT LOTS 1 & 2---LOT 1 Parcel No: 52440044000000000 County: JACKSON | Permit Holder: MCCOWN GORDON CONSTRUCTION LLC 850 MAIN ST KANSAS CITY, MO 64105 |
|--|---|

| |
|---|
| Activities Included for this Project: zNew Other - Commercial, License Tax, License Tax Credit, Paved Surface, Storm Sewer, Site Grading, |
|---|

| | | |
|---|---|------------------------------|
| Construction Type: Type VB (Unprotected) | Occupancy: Valuation: \$718,742.73 | Zoning District: CP-2 |
|---|---|------------------------------|

| | |
|--------------------------|--|
| Residential Area: | |
|--------------------------|--|

| | |
|------------------------|-----------|
| Commercial Area | 0 sq. ft. |
|------------------------|-----------|

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITTED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.
 NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

| |
|----------------------|
| Licensed Contractors |
|----------------------|

| |
|------------------|
| Fire Plan Review |
|------------------|

- 1 Provide documentation on the diesel tank for review and approval prior to installation.
- 2 Provide documentation on placarding of the diesel tank for review and approval prior to installation.

| |
|----------------------|
| Building Plan Review |
|----------------------|

Signature of
Applicant:

Date:

Print name:

Company Name:
